

**ADDENDUM NO. 3  
TO  
PLANS AND SPECIFICATIONS  
FOR  
2024 LAKE ICARIA RAW WATER PUMP STATION REPLACEMENT  
Corning Municipal Utilities  
Corning, Iowa**

**DETAILED SPECIFICATIONS**

**SECTION 11330 – HORIZONTAL CENTRIFUGAL PUMPS**

Page 11330-1, side heading "1.01 Description" after paragraph C insert the following:

"1. Aurora Pump 411 3x4x10C is an acceptable alternative Item."

**Clarification:** The Owner is responsible for painting the building interior walls, ceiling and exterior, if needed. The contractor will be required to paint the piping and other process related items supplied and installed by contractor.

I hereby certify that this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed Professional Engineer under the laws of the State of Iowa.

Signed:

Date:



April 29, 2024

Michael J. Shoup, P.E.

Iowa License No. 16922

My license renewal date is December 31, 2025



Detailed parts covered by this seal:

All